

Court Date:	April 3, 2009 - Cayuga
Defendant:	Anthony Elliott carrying on business as Elliott Electrical & Mechanical
City:	Kitchener ON
Site:	2405 North Shore Drive (Lowbanks) Dunnville, Couny of Haldimand
Charge(s):	(1) <i>Fail to Apply for Inspection</i> , Rule 2-004(1) ESC
	(2) <i>Fail to Apply for Inspection</i> , Rule 2-004(1) ESC
	(3) <i>Leave a Hazardous Condition</i> , Rule 2-200 ESC
	(4) <i>No Electrical Contractor's Licence</i> , Part VIII of the Electricity Act & O. Reg 570/05
Offence Date:	(1) Between February 1 st and March 21 st 2008
	(2) –(4) Between August 4 th and October 16 th 2008
Date Charge Laid:	February 11, 2009
Counsel/agent:	None
Plea:	Guilty to all counts
Disposition:	Charge (1): Fined \$1,000
	Charge (2): Fined \$1,000
	Charge (3): Fined \$1,500

	Charge (4): Fined \$2,000
--	---------------------------

Remarks:	Unlicensed contractor did panel change and rewiring, no permit filed and code defects found by ESA upon investigation
----------	---