

Court Date:	May 13, 2008 – Red Lake
Defendant:	Philip Danneman
City:	Red Lake ON
Site:	56 Discovery Rd, Red Lake ON
Charge(s):	(1) <i>No Electrical Contractor's Licence</i> , Part VIII of the Electricity Act & O. Reg 570/05
	(2) <i>Unsafe or Unguarded Electrical Conditions</i> , Rule 2-200 ESC
	(3) <i>Unauthorized Connection</i> ,
Offence Date:	December 17, 2008
Date Charge Laid:	n/a
Counsel/agent:	None
Plea:	Guilty (2counts)
Disposition:	Charge (1): Fined \$1,000
	Charge (2): Fined \$1,000
	Charge (3): Withdrawn
Remarks:	Mr. Danneman was called in to look at the wiring as the homeowner was experiencing brown out conditions. Danneman proceeded to remove the mast conduit and metebase, and disconnect the lines on the roof. He then connected the service conductors with marretts and left the scene. This work was all being done in a live state. Homeowner then contacted a Licensed EC to make the repairs.